

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 71 - Troja

CERTIFICATE

No.: 1031563

Product: Circuit-breakers

Type: BL 800

Rating: 800 A, 690 V AC

Ordering firm: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad

Manufacturer: OEZ s.r.o.
Šedivská 339, 561 51 Letohrad

Trade mark:

The test results are stated in the test-report No.: 302965-01/01 of: 18.08.2003

Application No.: 302965-01

A sample of the product was found to be in conformity with:
ČSN EN 55022:99+A1:01, ČSN EN 50081-2:96, ČSN EN 61000-6-4:02
ČSN EN 60947-1:00, ČSN EN 60947-2:98+A1:99

The validity of the certificate is limited to: 31.8.2006

18.9.2003

Prague

Pavel Kudma
Certification and Inspection Manager



Stamp